

Town of Athol BOARD OF HEALTH

584 Main St, Athol MA 01331 978-721-8450 dvondal@townofathol.org



WELL CONSTRUCTION PERMIT APPLICATION

TOWN OF ATHOL, MASSACHUSETTS BOARD OF HEALTH

To dig or drill a well in town required a well construction permit issued by the Board of Health in accordance with the Private Well Regulations and MGL Chapter 40, Sec. 54.

APPLICANT:		PHONE #	PHONE #:					
ADDRESS:		PH	PHONE #:					
PROPERTY OWNE	R:							
LOT LOCATION OF	WELL: Map #:	Parcel #:	[Can obtain from Assessors]					
STREET ADDRESS	S OF WELL:		the state of the s					
FEE: \$100.00 Paya	ble by check or money	order to the Town of Athol						
DECOMMISSION:								

A water supply certification from the Board must be issued for the use of a private well prior to the issuance of an occupancy permit for an existing structure or prior to the issuance of a building permit for new construction which is to be served by the well, pursuant to MGL Chapter 40, section 54. Requirements for certification are:

- 1. A well construction permit
- 2. A copy of the Water Well Completion Report as required by the Division of Water Resources (CMR 313, section 3.00)
- A copy of the Pump Test Report required pursuant to Section VII of the Athol Board of Health Regulations for Private Wells
- 4. A copy of the Water Quality Report required pursuant to Section VIII of the Athol Board of Health Regulations for Private Wells

List of	potential sources of contamination fo	r private wel	ls:							
1.	Subsurface Sewage Disposal Field	Requires:	100 Feet	Actual						
2.	Cesspool, Seepage Pit	Requires:	100 Feet	Actual						
3.	Septic Tank	Requires:	50 Feet	Actual						
4.	Sewer Line	Requires:	10 Feet	Actual						
5.	Defined Property Line	Requires:	10 Feet	Actual						
6.	Public Way (from def. Prop. Line)	Requires:	25 Feet	Actual						
7.	Driveways	Requires:	15 Feet	Actual						
8.	Swamps, Wetlands, Brooks	Requires:	25 Feet	Actual						
9.	Dwelling or other Structure	Requires:	5 Feet	Actual						
10.	Rights of Ways	Requires:	15 Feet	Actual						
11.	Other Potential Sources of Contaminat	ion:								
Attach map of proposed well location that 1) is an extended plot plan covering a radius of 200' around the proposed well, 2) identifies lateral distances of items 111 above, 3) owner of record must submit proof (receipt for certified mail or equivalent) that all owners of any properties abutting the subject property have been notified of the owner's intention to install a well.										
Permit	No: By:		Date:							

I WELL CONSTRUCTION PERMIT

The property owner or his designated representative shall obtain a permit from the Board of Health prior to the commencement of construction of a private well.

Each permit application to construct a well shall include the following:

- (1) The property owner's name, address, and telephone number.
- (2) The well driller's name, address, telephone number, and proof of valid state registration.
- (3) A plan with a specified scale, signed by a registered surveyor or engineer, showing the location of the proposed well in relation to existing or proposed above or below ground structures.
- (4) A description and location of visible prior and current land uses within two hundred (200) feet of the proposed well location, which represent a potential source of contamination, including but not limited to the following:
 - a. Existing and proposed structures
 - b. Subsurface sewage disposal systems
 - c. Subsurface fuel storage tanks
 - d. Public ways
 - e. Utility right-of-way within 500 1000 feet of the well site
 - f. Any other potential sources of pollution
- (5) Proof that the owner of any property abutting the applicant's property has been notified or the applicant's intention to install a well.
- (6) A permit fee of \$100.00.

The permit shall be on site at all times that work is taking place. Each permit shall expire on (1) year from the date of issuance unless revoked for cause. Permits may be extended for one additional six- (6) month period provided that the Board prior to the one-year expiration date receives a written request. No additional fee shall be charged for permit extension, provided there is no charge in the plans for the proposed well.

Well Construction Permits are not transferable.

II WELL LOCATION AND USE REQUIREMENTS

In locating a well, the applicant shall identify all potential sources of contamination which exist or are proposed within two hundred (200) feet of the site. When possible, the well shall be located upgradient of all potential sources of contamination and shall be as far removed from potential sources of contamination as possible, given the layout of the premises.

Each private well shall be accessible for repair, maintenance, testing, and inspection. The well shall be completed in a water bearing formation that will produce the required quantity of water under normal operating conditions.

Each private well shall be located at least ten feet from any property line. The centerline of a sell shall, if extended vertically, clear any projection from an adjacent structure by at least ten feet.

All private wells shall be located at least 25 feet, laterally, from the normal high water mark of any lake, pond, river, stream ditch, or slough. When possible, private water systems shall be located in areas above the 100-year floodplain.

A suction line or well shall be located a minimum of 10 feet from a building sewer constructed of durable corrosion resistant material with watertight joints, or 50 feet from a building sewer constructed of any other type of pipe; 50 feet from a septic tank; 100 feet from a leaching field; and 100 feet from a privy.

Water supply lines shall be installed at least 10 feet from and 18 inches above any sewer line. Whenever water supply lines must cross sewer lines, both pipes shall be constructed of class 150-pressure pipe and shall be pressure tested to assure water tightness.

The Board reserves the right to impose minimum lateral distance requirements from other potential sources of contamination not listed above. All such special well location requirements shall be listed, in writing, as a condition of the well construction permit.

No private well, or its associated distribution system, shall be connected to either the distribution system of a public water supply system or any type of waste distribution system.

III WATER QUALITY TESTING REQUIREMENTS

After the well has been completed and disinfected, and prior to using it as a drinking water supply, a water quality test shall be conducted.

A water sample shall be collected in accordance with "Standard Methods for the examination of water and wastewater". To ensure that proper procedures are followed, the sample shall be collected either by an authorized representative of a laboratory certified by the Commonwealth or Massachusetts, or by an agent for the Board of Health. Test results of samples taken by anyone other than those designated above will not be accepted.

A water sample shall be collected after purging three well volumes. The water sample to be tested shall be collected at the pump discharge or from a disinfected tap in the pump discharge line. In no event shall a water treatment device be installed prior to sampling.

The water quality test, utilizing EPA approved methods for drinking water and NOT methods used for analyzing wastewater, shall be conducted by a certified laboratory and shall include analysis for the following parameters:

A PARAMETER

MAX. ACCEPTABLE LIMIT

Coliform bacteria Nitrogen (nitrate) Turbidity	0/100 ml 10 mg/L 1 turbidity unit
Benzene	0.005 mg/L
Carbon tetrachloride	0.005 mg/L
Para-dichlorobenzene	0.005 mg/L
1,2 dichloroethane	0.005 mg/L
1,1 dichloroethylene	0.007 mg/L
1,1,1 trichloroethane	0.20 mg/L
Trichloroethylene	0.005 mg/L
Vinyl chloride	0.002 mg/L

B SODIUM

greater than 20 mg/L is of concern to persons on low sodium diets.

C INDICATOR PARAMETERS:

PARAMETER	RECOMMENDED UPPER LIMITS	RECOMMENDED LOWER LIMITS
Alkalinity	100 mg/L	30mg/L
Calcium Chloride	150 mg/L 250 mg/L	50mg/L
Color	15 color units	
Copper	1 mg/L	
Hardness	200 mg/L	50 mg/L
Iron	0.3 mg/L	
Magnesium	relative scale	
Manganese	0.05 mg/L	
Nitrogen (ammonia)	0.1 mg/L	0.015 mg/L
Nitrogen (nitrite)	1 mg/L	
Odor	3 threshold odor number	
рН	8.5	6.5
Potassium	relative scale	
Sediment	visual observation	
Sulfate	250 mg/L	
Total dissolved solids	500 mg/L	
Lead	.05 mg/L	

Following a receipt of the water quality test results, the applicant shall submit a Water Quality Report to the Board, which includes:

- 1. a copy of the certified laboratory's test results
- 2. the name of the individual who performed the sampling
- 3. from where in the system the water sample was obtained

The Board reserves the right to require re-testing of the above parameters, or testing for additional parameters when, in the opinion of the Board, it is necessary due to local conditions or for the protection of the public health, safety, and welfare. All costs and laboratory arrangements for the water testing are the responsibility of the applicant.



Town of Athol Board of Health



584 Main Street Athol, Massachusetts 01331 Suite #1 978-721-8450

Massachusetts State Certified Water Test Labs in our Area

Howard Labs 62 Main Street, Building #2 Hatfield, MA 01038 howardlaboratories.com 413-247-5533

Nashoba Analytical, LLC 31A Willow Road Ayer, MA 01749 Nashobaanalytical.com 978-391-4428

Quabbin Analytical Lab 9 Stadler Street Belchertown, MA 01007 413-323-7134 **ABUTTERS**: Owners of land that touches your property (adjacent to your land). All abutters need to be notified no matter how far their land is from your well site. If your well site is within 100 feet from the owners land across the street from your property, they need to be notified as well.

Ways to obtain proof that abutters have been notified of your intention to install a well: (Proof constitutes their signature.)

- 1. Deliver or mail a letter to abutters. Get their signatures acknowledging receipt of letter. Sample letter on back of this page.
- 2. Mail a certified letter to abutters. A certified letter has a postcard attached that the recipient signs. The postcard is mailed back to you and can be turned in to the Board of Health office as proof.

When you mail a certified letter it is always a good idea to also mail a letter regular mail. If the person refuses to sign for the certified letter they will still get the information in the regular mail. The refused letter will be returned to you, and constitutes proof of your attempt to the Board of Health.

If you don't know the name of the property owner, or if they live elsewhere, you can go to the Assessors Office in Town Hall for that information.

	Date
Dear,	
This is to inform you that we intend to ins	tall a well at:
This location is adjacent to your property. At you. If you have any questions concerning the office at (978) 249-7934.	
Please sign below to acknowledge you have	ve received notification and return it to n
Thank you for taking the time to acknowledge	e this letter.
Sincerely,	
C' CAL W	
Signature of Abutter	Date



 	***************************************	\neg
 	 	-
		- 1

	Note: GPS coordinates must be in WGS84 datum, in degrees. decimal degree format.																
1. WELL LOCATION GPS (Required) North																	
Address at Well Location																	
Subdivision/Property Description												· · · · · · · · · · · · · · · · · · ·					
City/Town M												· · · · · · · · · · · · · · · · · · ·					
Assess	ors Map								City/To	own					-		
Board o	f Health	n permit	obtain	ed	Yes	☐ Not R	Required		Permit	Numbe	er		D	ate Issued			
2. WOF	K PER	FORME	ED .	3. WELL	ГҮРЕ		4. DRILL										
							Overburg	den	Bedro	ock	Developed		Y 🗆 I	N Fracture Enhance	Fracture Y N		
5. WEL	L LOG	OV	ERBUF	RDEN LITHO	LOGY	Drop in	Ex Fas		of Fluid		Disinfected Y N Surface Seal						
From (ft)	To (ft)	Code	Color	Comr	nent	Drill Stem	Sid	wc			Total Well			Depth to	Type LJ LJ Depth to		
							N DFDS				Depth			Bedrock			
											7. CASING						
											From T	0	Туре	Thickne	SS	Diameter	
												╌┼	井井	=			
						OY ON					8. SCREEN						
											From T	0	Туре	Slot Siz	e	Diameter	
						OY ON]			
5. WEL	L LOG	BEDF	ROCK L	LITHOLOGY	Drop	Extra	Extra Fast or	Loss	or \	/isible]			
From	То	Code		Comment	In Drill Stem	Large	Slow Addi		ition Rust	9. WATER-BEARING ZONES							
(ft)	(ft)	Code					Rate				From			То		Yield (gpm)	
						N T Y T N											
											10. PERMANENT PUMP (IF AVAILABLE)						
						N D Y D N					N Dump						
											Description		الــالــ	Horsepo	wer		
	.,										Pump Intake	, (ca.		Nominal Pump			
				44/	OY O	NUYUN	□ F 🗆 S	S 🗆 L [] A []	Υ□N				ft Capacity		gpm	
11. AN	NULAR	SEAL	/ FILTE	ER PACK								-			SALAR SHAREST	en Loop only)	
From	То	Mat	erial 1	Weight	Material 2	Weight Wa	ater (gal)	Batches		od of ement	Therma Conductiv			hermal ffusivity		Formation Water	
4.10											(BTU/hr·ft·	°F)	(f	t ² /day)	Ten	nperature (°F)	
										<u> </u>	,						
			Ш							Ш	DEP UIC#	14 14	/ATER		m this	well 🗆 Y 🔲 N	
13. WELL TEST DATA Time Pumped Pumping Level Time to Recover						Recovery		ate	Static	П	Flowing						
Da	te	M	ethod	Yield (G	PM) (hrs		(ft BGS		(hrs)	(min)	(ft BGS)		asured	Depth BGS	(ft)	Rate (gpm)	
15. COMMENTS This well was drilled or altered under my direct supervision, according to the applicable rules and regulations, and this																	
16. WI	ELL DR	ILLERS	STAT	EMENT	report is co	mplete and a	accurate t	o the b	est of m	y know	ledge.		0				
Driller	*					Supervising								rtification #			
Compa	Company Date Job Complete Rig Permit #									Rig	Permit #						

Report to be filled out by well driller online to DEP * A copy must be sent to Athal Health Department